ADDENDUM NO. 2

July 21, 2016



PROJECT:	An Exterior Renovation Project for the Fern Ridge School District
	District Administration Offices
	88834 Territorial Road
	Elmira, Oregon 97437
OWNER:	Fern Ridge School District
	88834 Territorial Road
	Elmira, Oregon 97437

ARCHITECT: Paul L. Bentley, Architect AIA PC 615 SE Jackson Street Roseburg, Oregon 97470

The original drawings dated June/July 2016 and Addendum No. 1 dated July 18/19, 2016, are hereby amended and supplemented by Addendum No. 2 dated July 21, 2016.

SPECIFICATIONS

INVITATION TO BID:

See the attached revised bid form with unit pricing.

PRE BID CLARIFICATIONS: See the attached clarifications.

Interior finishes of doors which are being infilled will be gypsum board, painted with primer, texture, primer, and 2 cts semi-gloss paint as specified. No vinyl wall covering patch required.

An interior office will be furnished to serve as a job office for the contractor.

GC is responsible for job site portable toilet.

As discussed at the pre bid, due to the age of the building the contractor shall assume lead based paint is present and bid accordingly.

DRAWINGS

SHEETS M2.1, M2.2, M2.3, M6.1 AND M6.2 MECHANICAL PLANS & DETAILS:

See revised sheets which clarify separation of base bid work and alternate work.

SHEET E2.1 FIRST FLOOR ELECTRICAL PLAN:

See revised sheet which clarify separation of base bid work and alternate work.

END OF ADDENDUM NO. 2

ATTACHMENTS: REVISED INVITATION TO BID MECHANICAL SHEETS M2.1, M2.2, M2.3, M6.1, M6.2 ELECTRICAL SHEET E2.1

FERN RIDGE SCHOOL DISTRICT 28J

88834 Territorial Rd Elmira, OR 97437

INVITATION TO BID

Renovations of Fern Ridge District Office

Bids Due: Thursday, July 28, 2016 Time Due: 2:00 pm, PST

Business Manager:

Quanah Bennett Phone: (541) 935-2253 Email: qbennett@fernridge.k12.or.us

INVITATION TO BID

The FERN RIDGE SCHOOL DISTRICT 28J (District) invites qualified Respondents to submit bids to construct the renovations of the District Office. Bids are due by 2:00 pm, PST, on Thursday, July 28, 2016. The District reserves the right to reject any or all bids; this invitation to bid does not obligate the District to accept or contract for any expressed or implied services. The successful bidder must comply with the District's equal opportunity requirements.

SCOPE OF WORK

The scope of the project is to consists of a complete removal of existing siding and trim down to existing sheathing on all exterior walls, demolition and replacement of all windows and coverings, shingle roofing removal and replacement, new gutters and downspouts, new concrete ramps and steps, HVAC upgrades (Alternate bid), and various other repairs and renovations to the District Offices, 88834 Territorial Road, Elmira, Oregon, as shown on Contract Documents prepared by Paul L. Bentley Architect, A.I.A., dated June 2016 and July 2016.

The successful bidder will perform all work described in the construction documents for the project.

WALKTHROUGH

There will be a mandatory, pre-bid walkthrough to give prospective bidders a better understanding of the project. The mandatory walkthrough will be at 2:00 pm on Tuesday July 12th, 2016, at the District Office at 88834 Territorial Road, Elmira, OR, 97437. The meeting will begin in the conference room at the District Office followed by a walkthrough of the building. All bidders must attend the meeting to qualify to submit bids on the project.

SUBMISSION REQUIREMENTS

To qualify as a responsive submission, the submittal must be fully completed. An authorized representative must sign the Statement of Assurances in ink. Submittals can be mailed or hand delivered to Fern Ridge School District 28J, 88834 Territorial Rd, Elmira, OR 97437. Responses must be received by 2 pm on July 28, 2016.

BID OPENING

Bids will be accepted until 2:00 pm PST on Thursday, July 28, 2016. Bids must be received on or before that time; postmarks or other proof of dispatch ARE NOT acceptable as delivery by the time set. Bids will be opened at the district office after the bid time closes. Pursuant to ORS 279C.370, for contracts with an estimated value of more than \$100,000, contractors will have until 4:00pm PST on July 28, 2016 to submit disclosure of the first tier subcontractors, if any.

BID FORM

Each bidder must identify whether the bidder is or is not a resident bidder, as defined in ORS 279A.120. No bidder or subcontractor can be considered if the bidder or a subcontractor is on the current list of contractors ineligible to receive public works contracts as published by the Commissioner of the Bureau of Labor and Industries (BOLI).

No offer will be considered by the District unless the offeror has acknowledged that Contractor agrees to be bound by and will comply with the provisions of ORS 279C.838, 279C. The District shall pay the required prevailing wage fee to BOLI.

No offer will be considered by the District unless the offeror is registered with the Oregon Construction Contract Board. The Contractor need not be licensed for asbestos abatement. Every Contractor and subcontractor must have a public works bond filed with the Commissioner of the Bureau of Labor and Industries before starting work, unless exempt.

Each bidder must certify that there has been no discrimination against minority, women or emerging small business enterprises in obtaining any subcontracts. Bidders are encouraged to include minority, women or emerging small business enterprises as subcontractors.

Instructions for First-Tier Subcontractor Disclosure: Bidders are required to disclose information about certain first-tier subcontractors when the contact value for a public Improvement is greater than \$100,000. Specifically, when the contract amount of a first-tier subcontractor furnishing labor or labor and materials would be greater than or equal to:

- i. Five percent of the project Bid, but at least \$15,000; or
- ii. \$350,000 regardless of the percentage.

The Bidder must disclose the following information about that subcontract either in its Bid submission, or within two hours after Bid Closing:

- A. Subcontractor's name;
- B. Category of work that the subcontractor would be performing, and
- C. Dollar value of the subcontract.

If the Bidder will not be using any subcontractors that are subject to the above disclosure requirements, the Bidder is required to indicate "NONE" on the accompanying form.

THE DISTRICT MUST REJECT A BID IF THE BIDDER FAILS TO SUBMIT THE DISCLOSURE FORM WITH THIS INFORMATION BY THE STATED DEADLINE (OAR 137-049-0360)

SPECIFICATIONS AND ADDENDA

Any addenda will be posted at the same location as the bid document, labeled as "ADDENDUM" and numbered in order of issuance. Requests for notification can be made by sending an email to the Business Manager.

SELECTION PROCESS

Anticipated selection process:

- Bids will be reviewed for completeness after opening. Incomplete bids will be set aside.
- Completeness determinations will be made within 24 hours of bid closure.
- Notice of intent to award will be issued within 24 hours of bid openings
- Any protest of this solicitation must be submitted within seven days of the issuance of the solicitation. Any protest of the intent to award must be filed within two business days of the issuance of the notice of intent.

Any protest must be filed in writing with the District. The protest must indicate the nature of the objection, and must be sufficiently detailed for a neutral observer to discern the specific matter being objected to. Protests will be reviewed by the District and, if not resolved, will be submitted to the District's Board of Directors. The decision of the Board of Directors is final.

The District will select the lowest cost Responsible Bidder. To be considered a Responsible Bidder, a bidder must submit a bid that demonstrates Bidder's qualifications to perform the work in terms of staff qualifications, past related experience, and references. Bidders who cannot demonstrate satisfactory performance of at least two similar projects in similar circumstances will not be considered qualified.

The selected Respondents and all others who submitted Bids will be notified of the District's selection.

Additional Notes:

In evaluating the bids and selecting a Respondent, the District reserves the following rights:

- To reject any bid not in compliance with the bid document or applicable procedures and requirements, and may reject for good cause any or all bids when it is in the public interest to do so;
- To issue subsequent requests for bids, if desired;
- Not to award a contract and cancel the process;
- To waive any minor irregularities or informalities in any bid;
- To negotiate with any Respondent to further amend, modify, refine, or delineate its bid, and the contract price as it is affected by such negotiation of scope of work, and specific contract terms;
- This Invitation to Bid does not constitute an offer to contract.
- There is no expressed or implied obligation for the District to reimburse responding bidders for any expenses incurred in preparing, submitting, or presenting Bids in response to this request.

END OF PAGE

ATTACHMENT A INVITATION TO BID RESPONSE

Respondent Information

Bidder Name:
Office Address:
Office Phone Number:
Contact Name/Title:
Contact Email:
Contact Phone and Email:
Construction Contractor's Board License #:

- 1. Please include a signed Statement of Assurances (Attachment B).
- 2. Please include a pricing proposal, in the form of completion of a signed Attachment C.
- 3. Please include a completed subcontractor disclosure form, Attachment D. You must enter "NONE" if there are no subcontractors that need to be disclosed.

Summary:

Please complete and submit information requested in Attachment A, B, C and D.

ATTACHMENT B STATEMENT OF ASSURANCES

- 1. The undersigned attests that he/she has the authority and/or responsibility to represent the organization submitting this Bid in all phases of the Invitation to Bid process and in this Statement of Assurances. The undersigned understands that any false or substantially incorrect statement in the Invitation to Bid may disqualify this Bid from further consideration or be cause for termination of any future Contract.
- 2. Respondent understands that this Invitation to bid is considered an integral part of the Request for Bid, and terms shall be binding on the Respondents. Failure of the successful bidder to accept these obligations in a Contract as authorized by the Statement of Assurances may result in cancellation of an award.
- 3. Respondent understands that in responding to this Invitation to Bid, Respondent certifies that the organization he/she represents is in compliance with all Oregon Tax laws described in ORS 305.380(4) and agrees to comply with all applicable federal, state, and local laws, regulations and requirements related to the Invitation to Bid and performance of any resulting Contract, including but not limited to those referenced in this Invitation.
- 4. Respondent certifies that Respondent can meet the insurance requirements check marked in Appendix D of the proposed Contract (Insurance Coverage Required) and that Respondent understands that such coverage must be kept active during the entire term of the Contract, if selected. The Respondent is a (check one) ____ resident Respondent or ____ nonresident Respondent of the State of Oregon as defined in ORS 279A.120.
- 5. Respondent, if selected as Contractor, agrees to be bound by and will comply with the provisions of ORS 279C.838 and 279C.840.
- 6. The Representative's Signature below is certification that there has been no discrimination against minority, women or emerging small business enterprises in obtaining any subcontracts.

I, the undersigned, have read and thoroughly understand the Invitation to Bid instructions and all other conditions of Invitation to Bid issued by the FERN RIDGE SCHOOL DISTRICT 28J and agree to abide by and fulfill the requirements thereof if awarded the Contract as a result of this Invitation to Bid.

Respondent Name:
Authorized Representative's Signature:
Type or Print Name & Title:
Date:

ATTACHMENT C **PRICING PROPOSAL**

1.	The undersigned (check one of the following and insert information requested)	,
	NAME of FIRM:	
-	A corporation organized and existing under the laws of the State of; or	
-	A partnership registered under the laws of the State of	; or
-	An individual proprietorship doing business under an assumed business na under the laws of the State of	ame registered
-	after having carefully examined the bidding documents and addenda numbered inclusive, as well as the work site and conditions affecting the work, hereby agrees to furnish all labor, materials, and all other work, required by and in strict co he above documents, necessary to complete the project for the stipulated sum of:	proposes and
Base Bio	d:	
A. [District Office Remodel	
TOTAL (Figures): \$	_Dollars
TOTAL (Words): \$	_Dollars
Alternate	es:	
Alternate	#1 HVAC Upgrades:	
TOTAL A	ADD (Figures) \$	Dollars
Alternate	#2 Window Coverings:	
TOTAL A	ADD (Figures) \$	Dollars
Alternate	#3 Civil Work:	
TOTAL A	ADD (Figures) \$	Dollars

The undersigned also proposes to furnish all labor and materials, and perform all work relating to the following Unit Prices, as more fully described in Section 01026, Unit Prices.

UNIT PRICE SCHEDULE

Extra/Credit

Replace 2 x 4 wall framing due to dryrot conditions:	per LF of wall
Replace 2 x 10 Rim Joist due to dryrot conditions:	per LF of Joist
Replace 1 x 4 diagonal sheathing due to dryrot:	per SF of Wall/Roof
Replace 2 x 12 fascia board, wrapped in metal:	per LF of fascia

- 2. The undersigned agrees to maintain the proposal price for a period of 30 calendar days after bid opening.
- 3. The undersigned agrees, if awarded a contract, to complete all work as shown in the Contract Documents by the substantial completion date listed below.
- 4. The undersigned agrees that, prior to commencement of the Work, and within 7 calendar days of Notice of Intent to Award, to:
 - A. Enter into and execute a contract for the work in the form of Fern Ridge School District, "Construction Contract".
 - B. Deliver to the Owner duly executed AIA Document G705, "Certificate of Insurance," or ACORD form 25S.
 - C. Deliver to the Owner duly executed AIA Document A312, "Performance Bond and Payment Bond."
- 5. The undersigned certifies that this Bid has been prepared independently and is not made in the interests of any undisclosed party. It is submitted without collusion or intent to limit independent, competitive bidding. The Bidder has in no way induced or solicited other Bidders to submit false bids, or to refrain from bidding.
- 6. The undersigned agrees that the provisions of ORS 279C.515 to 279C.545 and 279C.800 to 279C.970 pertaining to prevailing wage rates will be included in the Agreement if applicable.
- 7. Indicate below whether Bidder is Resident or Non Resident bidder. "Resident Bidder" means a bidder that has paid unemployment taxes or income taxes in Oregon during the twelve calendar months immediately preceding submission of bid, has a business address in this state and has stated in the bid whether the bidder is a "Resident Bidder" pursuant in 279C.365.
- 8. The undersigned certifies that you visited the site and thoroughly investigated all existing conditions.
- 9. Security Deposit

a. Bids shall be accompanied by a security deposit as follows: Bid Bond of a sum no less that 10 percent on AIA A310 Bid Bond Form

b. Endorse the Bid Bond in the name of Fern Ridge School District as oblige, signed and sealed by the principal (Contractor) and surety

Item:

c. The security deposit will be returned after delivery to the Fern Ridge School District of the required Performance and Payment Bond by the accepted bidder

- d. Include the cost of the bid security in the Bid Amount
- e. If no contract is awarded, all security deposits will be returned.
- 10. Start of construction after contract execution and permitting is June 15, 2015. Substantial Completion is August 28, 2015. Final Completion is September 4, 2015. (Unless Dates changed by Addenda)
- 11. If applicable the first tier subcontractor disclosure form is due 2 hours after bid closing.
- 12. Submittals are due promptly after Letter of Intent. A Pre-Construction Meeting will be held prior to commencement, Weekly Construction meetings are required.

SIGNATURES

Oregon Construction Contractor's Board No	Federal Tax ID:
Address:	
Telephone:	
Signature:	
Date:	
Printed Name:	
Title:	

ATTACHMENT D FIRST TIER SUBCONTRACTOR DISCLOSURE FORM

List below the name of each subcontractor that will be furnishing labor or will be furnishing labor and materials and this is required to be disclosed, the category of work that the subcontractor will be performing and the dollar value of the subcontract. <u>Enter "NONE" if there are no subcontractors that need to be disclosed.</u>

Subcontractor Name	Category of Work	Dollar value


Failure to submit this form by the disclosure deadline (Thursday, July 28, 2016 at 4:00 pm PST) will result in a nonresponsive bid. A nonresponsive bid will not be considered for award.

Respondent Name: _____


Authorized Representative's Signature: _____

Type or Print Name & Title: ______


Date: _____










1 OF 5















OF 5













OF 5


MECHANICAL LEGEND	VENTILATION AIR SCHEDULE -	FERN RIDGE DISTRICT OFFICE			FLEXIBLI 48" MAX
Image: Supply air diffuser AFF ABOVE FINISH FLOOR Image: Supply air diffuser B.D. BOTTOM OF DUCT Image: BHP BRAKE HORSEPOWER	ROOM NUMBER AREA (SQ. FT.) AND NAME		SIDE AIR RED (CFM) ZONE SUPPLY PRIMARY RETURN EXHAU OSA AIR (CFM) OSA AIR (CFM) AIR (CF (CFM) FRACTION	ST Zone Corrected	AIR SYSTEMS
CONN. CONNECTIONAL AIR FLOW CONSTIC COLD WATER	Az OFFICE 1 141 TECHNOLOGY WORK SPACE 4 245 OFFICE 5 134 OFFICE 6 91	Pz Rp Ra 5 1 5 0.06 5 2 5 0.06 5 1 5 0.06 5 1 5 0.06 5 1 5 0.06 5 1 5 0.06	Vbz Ez Voz Vpz Zp 13 1.0 13 100 0.13 100 0 25 1.0 25 200 0.12 200 0 13 1.0 13 125 0.10 125 0 10 1.0 10 100 0.10 100 0	Evz 1.06 1.07 27 1.09 14 1.09 11	(E)F-1 SEISMIC (E)F-1 TA (E)F-1 TA (E)F-1
Image: Supply or outside air DB DRY BULB Image: Supply or outside air DIA. DIAMETER Image: Duct up & down DIST. DISTRIBUTION Image: Duct up & down EA EXHAUST AIR Image: Duct up & down EB ENTERING DRY BULB TEMPERATUR Image: Duct up & down EWB ENTERING WET BULB TEMPERATUR		$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	1.06 11 1.03 71 1.10 5 1.02 9 0.91 101 0.93 137	(E)F-1 (E)F-1 (E)F-1 (E)F-1 (E)F-1 (E)F-1 (E)F-1
Image: Supply or outside air Supply or outside air Image: Supply or outside air FPM Image: Supply or outside air FPS	TOTAL 2548	34	367 367 1900 1800 140 Vou Vps		MANUAI SPIN-IN 0.21
Image: Construct of a down FT. FEET / FOOT Image: Construct of a down GALLONS PER MINUTE Image: Construct of a down H Image: Construct of a down H <td>OFFICE 2 200 OFFICE 3 271 WORK ROOM 9 490 OFFICE 10 193 OFFICE 11 196</td> <td>5 1 5 0.06 5 2 5 0.06 5 3 5 0.06 5 1 5 0.06 5 1 5 0.06 5 1 5 0.06 5 1 5 0.06</td> <td>17 1.0 17 150 0.11 150 0 26 1.0 26 175 0.15 175 0 44 1.0 44 300 0.15 300 0 17 1.0 17 100 0.17 100 0 17 1.0 17 100 0.17 100 0</td> <td>1.04 19 1.00 29 1.01 50 0.99 19 0.99 19</td> <td>F-2 F-2 F-2 F-2 F-2 F-2</td>	OFFICE 2 200 OFFICE 3 271 WORK ROOM 9 490 OFFICE 10 193 OFFICE 11 196	5 1 5 0.06 5 2 5 0.06 5 3 5 0.06 5 1 5 0.06 5 1 5 0.06 5 1 5 0.06 5 1 5 0.06	17 1.0 17 150 0.11 150 0 26 1.0 26 175 0.15 175 0 44 1.0 44 300 0.15 300 0 17 1.0 17 100 0.17 100 0 17 1.0 17 100 0.17 100 0	1.04 19 1.00 29 1.01 50 0.99 19 0.99 19	F-2 F-2 F-2 F-2 F-2 F-2
Instide Diameter	LOBBY 16 442 MENS WC 17 128 OFFICE 18 90 MEETING 19 198 ANTEROOM 20 86	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$	0.98 58 1.00 9 1.02 12 0.97 41 1.02 11 0.89 15	F-2 F-2 F-2 F-2 F-2 F-2 F-2 F-2
Image: Connect to existing MAX. MAX. MAX.MUM Image: Connect to existing MBH MBH MBH MINIMUM Image: Connect to existing MBH MIN. MINIMUM Image: Connect to existing MBH MINIMUM MINIMUM Image: Connect to existing MBH MINIMUM MINIMUM Image: Connect to existing MINIMUM MINIMUM <td>STORAGE 21 110 OFFICE 22 248 OFFICE 23 210 TOTAL 2862</td> <td>5 2 5 0.06 5 2 5 0.06</td> <td>25 1.0 25 200 0.12 200 0 23 1.0 23 150 0.15 150 0 298 298 1925 1875 70 Vou Vps 1875 70</td> <td>1.03 28 1.00 25</td> <td>F-2 F-2</td>	STORAGE 21 110 OFFICE 22 248 OFFICE 23 210 TOTAL 2862	5 2 5 0.06 5 2 5 0.06	25 1.0 25 200 0.12 200 0 23 1.0 23 150 0.15 150 0 298 298 1925 1875 70 Vou Vps 1875 70	1.03 28 1.00 25	F-2 F-2
Image: Note of the second s			ED TOTAL OUTDOOR AIR FLOW RATE 335 CFM Correcto		0.17
? Legon Mentre Designation P PERSON D P D P D P D P D P D P D P D P D P P P		IPER MAX MIN DAMPER WIDE OPEN (PE CFM CFM SIZE STATIC LOSS	FURNACE WITH HEAT PUMF	F $1-$	M6.1 NOTE 1/4" galv. threade of wood member (
Image: State of the control of the	NUMBER 1-1 F-1 VVT D 1-2 F-1 VVT D	"H20 AMPER 100 33 6 0.05 AMPER 200 67 8 0.05	NUMBER SYSTEM TYPE	WEST CONDENSING	USE MACHINE THREAD 1/4" WASHER @ EAC ATTACH TO TOP COR
SQ. SQUARE TEMP. TEMPERATURE TYP. TYPICAL VAV VARIABLE AIR VOLUME	1-4 F-1 VVT D 1-5 F-1 VVT D	AMPER 125 42 6 0.05 AMPER 100 33 6 0.05 AMPER 400 133 10 0.05 AMPER 75 25 6 0.05	CONFIGURATION SITE ELEVATION (FT)	HORIZONTAL 400	JOIST W/ #12 X 1- WOOD MATERIAL EDG W/ (2) #12 TEK SC
W WIDTH WB WET BULB WPD WATER PRESSURE DROP Ø WORTER	(1-8 F-1 VVT D	AMPER2759280.05AMPER400133100.05S DAMPER11170160.05		1800 YES	
Prince PRESSURE GAUGE (E) EXISTING T	2-2 F-2 VVT D 2-3 F-2 VVT D	AMPER 150 50 6 0.05 AMPER 175 58 6 0.05 AMPER 100 33 6 0.05 AMPER 300 100 8 0.05	MIN. OSA (CFM) EXTERNAL SP. ("H2O) DISCHARGE DIRECTION	335 .70 LEFT	
Image: Image: Advance of the constraint of the constr	2-5 F-2 VVT D. 2-6 F-2 VVT D. 2-7 F-2 VVT D.	AMPER 100 33 6 0.05 AMPER 250 83 8 0.05 AMPER 200 67 8 0.05	FILTER TYPE FILTER MEDIA AREA (SQ FT)	2" MERV 8 5.0	
品 ····································	2-9 F-2 VVT D 2-10 F-2 VVT D	AMPER 150 50 6 0.05 AMPER 200 67 8 0.05 AMPER 300 100 8 0.05 S DAMPER 1283 0 16 0.05	HEATER KW HEATER AMPS	15 54.2/59.9	
SMOKE DETECTOR	5.11	EXHAUST FANS	HEATER + MOTOR MCA HEATER + MOTOR MOCP VOLTAGE-PHASE	76.3/83.4 80/90 208/230-1	TOP VIEW
SEISMIC BRACING		MARK NUMBER TYPE INLINE	HEAT PUMP UNIT MARK NUMBER		
LONGITUDINAL BRACING		SYSTEMBASEMENTCFM1300TOTAL SP. (IN H20).25	NOMINAL UNIT SIZE (TONS) SENSIBLE (MBH) ENT. EVAP AIR TEMP (DB/WB.)	5 60 80/65	
		RPM1707MOTOR HP1/10CONTROLLED BY1SEE 3/M6.2	AMBIENT AIR (*F) EFFICIENCY (SEER)	92 14	$ \begin{array}{c} 2 \\ M6.1 \\ \hline SCAL \end{array} $
		INTERLOCK WITH - DAMPER TYPE 1 AT HOOD	HSPF REFRIGERANT	11.5 R-410A	
AIR DISTRIBUTION DETAILS		ISOLATIONEXTERNALDESIGN WEIGHT (LBS)60MAX. SONES8.5	FURNACE BASIS OF DESIGN FURNACE WEIGHT INCLUDING COIL (LBS) FURNACE ELECTRICAL (V/\$\phi\$) (POWER)	CARRIER FV4C 210 115/230-1	HANG FA WITH MC
	MAX.	ELECTRICAL (V/\$\$) (POWER) 115/1 1/10HP BASIS OF DESIGN GREENHECK SQ-85-VG	HEAT PUMP BASIS OF DESIGN HEAT PUMP WEIGHT (LBS) HEAT PUMP ELECTRICAL (V/ϕ) (POWER)	CARRIER 25HCE 250 208/230-1	FLEXIBLE
TOP DUCT TURNING VANES IN ALL SQUARE ELLS AND TEES LAGGED DUCTWORK RECT. TO RECT. DUCT CROSSING t	RECT. TO ROUND		NOTES: 1. PROVIDE TXV, CRANKCASE HEATER AND HI LOW S UNITS. 2. PROVIDE INTEGRAL DISCONNECT FOR ALL FAN CO	SWITCH FOR ALL	




UNITS. 2. PROVIDE INTEGRAL DISCONNECT FOR ALL FAN COIL UNITS.













4 Ĺ

315 SE Jackson Stree Roseburg, OR 9747 541.672.0273 offic 541.673.7560 fa , O

