



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported 9/28/2017

WO#: 1709619
CLIENT: Elmira High/Elementary School
Project:
PWS Number: OR4191805
Sample Source: DIST-A

Received Date: 9/15/2017 11:20:00 AM
Sampler Name: Jeff Thiessen
Matrix: Drinking Water
Sample Type: Routine

Lab ID: 1709619-001	Client Sample ID	Kit Sink	Collection Date: 9/15/2017 6:30:00 AM					
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	ND	1.30	0.100		mg/L	9/22/2017 11:28:00 AM	KG
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/27/2017 7:25:00 AM	KG

Lab ID: 1709619-002	Client Sample ID	Espresso Bar Sink	Collection Date: 9/15/2017 6:55:00 AM					
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	0.698	1.30	0.100		mg/L	9/22/2017 11:28:00 AM	KG
Lead	SM 3113 B	0.0375	0.0150	0.00400	*	mg/L	9/27/2017 7:25:00 AM	KG

Lab ID: 1709619-003	Client Sample ID	Senior Hall D.F.	Collection Date: 9/15/2017 6:50:00 AM					
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	ND	1.30	0.100		mg/L	9/22/2017 11:28:00 AM	KG
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/27/2017 7:25:00 AM	KG

Lab ID: 1709619-004	Client Sample ID	Health Room	Collection Date: 9/15/2017 6:55:00 AM					
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	ND	1.30	0.100		mg/L	9/22/2017 11:28:00 AM	KG
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/27/2017 7:25:00 AM	KG

Lab ID: 1709619-005	Client Sample ID	Shop D.F.	Collection Date: 9/15/2017 6:40:00 AM					
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	0.101	1.30	0.100		mg/L	9/22/2017 11:28:00 AM	KG
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/27/2017 7:25:00 AM	KG

Lab ID: 1709619-006	Client Sample ID	Gym Hall D.F.	Collection Date: 9/15/2017 6:45:00 AM					
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	ND	1.30	0.100		mg/L	9/22/2017 11:28:00 AM	KG
Lead	SM 3113 B	0.00247	0.0150	0.00200		mg/L	9/27/2017 7:25:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Analytical Report

Date Reported 9/28/2017

WO#: 1709619
CLIENT: Elmira High/Elementary School
Project:
PWS Number: OR4191805
Sample Source: DIST-A

Received Date: 9/15/2017 11:20:00 AM
Sampler Name: Jeff Thiessen
Matrix: Drinking Water
Sample Type: Routine

Lab ID: 1709619-007 Client Sample ID: CafA D.F. Collection Date: 9/15/2017 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	ND	1.30	0.100		mg/L	9/22/2017 11:28:00 AM	KG
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/27/2017 7:25:00 AM	KG

Lab ID: 1709619-008 Client Sample ID: Elmira Elem Hall D.F. Collection Date: 9/15/2017 7:10:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	0.299	1.30	0.100		mg/L	9/22/2017 11:28:00 AM	KG
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/27/2017 7:25:00 AM	KG

Lab ID: 1709619-009 Client Sample ID: Elmira Elem Kit Sink Collection Date: 9/15/2017 7:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	0.386	1.30	0.100		mg/L	9/22/2017 11:28:00 AM	KG
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/27/2017 7:25:00 AM	KG

Lab ID: 1709619-010 Client Sample ID: Elmira Elem Health Room Collection Date: 9/15/2017 7:10:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	0.329	1.30	0.100		mg/L	9/22/2017 11:28:00 AM	KG
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/27/2017 7:25:00 AM	KG

Qualifiers: * Value exceeds Maximum Contaminant Level (MCL) A Accredited by ORELAP
C Value is below Minimum Compound Limit E Value above quantitation range
H Holding times for preparation or analysis exceeded LOD Limit of Detection
MCL Maximum Contaminant Level NAR See note in Case Narrative
ND Not Detected at the Reporting Limit PL Permit Limit