



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Analytical Report

Date Reported 10/9/2017

WO#: 1710007
CLIENT: Fern Ridge School District
Project: Veneta Elementary / Lead & Copper
PWS Number:
Sample Source:

Received Date: 10/2/2017 10:50:00 AM
Sampler Name: J. Thiessen
Matrix: Drinking Water
Sample Type:

Lab ID: 1710007-001 **Client Sample ID:** Coffee Cart **Collection Date:** 10/2/2017 7:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	ND	1.30	0.100		mg/L	10/9/2017 8:15:00 AM	KG
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	10/8/2017 12:22:00 PM	KG

Lab ID: 1710007-002 **Client Sample ID:** Gym DF **Collection Date:** 10/2/2017 6:50:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	0.332	1.30	0.100		mg/L	10/9/2017 8:15:00 AM	KG
Lead	SM 3113 B	0.00214	0.0150	0.00200		mg/L	10/8/2017 12:22:00 PM	KG

Lab ID: 1710007-003 **Client Sample ID:** Room 2 **Collection Date:** 10/2/2017 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	0.376	1.30	0.100		mg/L	10/9/2017 8:15:00 AM	KG
Lead	SM 3113 B	0.00427	0.0150	0.00200		mg/L	10/8/2017 12:22:00 PM	KG

Lab ID: 1710007-004 **Client Sample ID:** Room 19 **Collection Date:** 10/2/2017 6:55:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	0.770	1.30	0.100		mg/L	10/9/2017 8:15:00 AM	KG
Lead	SM 3113 B	0.00603	0.0150	0.00200		mg/L	10/8/2017 12:22:00 PM	KG

Lab ID: 1710007-005 **Client Sample ID:** Hall DF **Collection Date:** 10/2/2017 6:52:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analys
Copper	SM 3111 B	0.495	1.30	0.100		mg/L	10/9/2017 8:15:00 AM	KG
Lead	SM 3113 B	0.00307	0.0150	0.00200		mg/L	10/8/2017 12:22:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit