

Elmira Elementary School HASS Testing Summary

11/30/2022

Mandatory water testing for lead was initially conducted at Elmira Elementary School. A total of 69 fixtures were tested. The results were received on 12/12/2022 and it was pleasant news. There are only two fixtures that showed elevated levels above the acceptable level of 15 ppb. These fixtures failed and were immediately removed from service until a permanent solution can be implemented.

Update - 1/26/2023

Fixture #65 - It was determined to be surplus and is not actively used. It was permanently removed from service. The water supply was terminated, handles removed and the access panel locked. There are no current plans to have this fixture returned to service. No further testing or remediation is needed at this time.

Fixture #67 - This is a frequently used fixture during the field sport seasons but seldom used the rest of the year. The fixture, by design, is a low lead hydrant used for providing potable water. After a conversation with the state ODE representative who oversees the HAAS testing, it was determined that retesting was appropriate in determining if it was initially a false positive. Following the approved retesting protocol, the faucet was retested on 1/19/2023. The retest showed that it is well within the acceptable range with a result of ND (not detected). No further testing or remediation is needed at this time.