

Veneta Elementary School (VES) - 208403

2022-2023 Test

Map Index #	Fixture Location/Description	Fixture ID #	Initial Collection Date	Result (ppb)	Action Taken	Comments	1st Retest Date
1	Front Office Health Room Restroom	20840300-001BF		ND			
2	Staff Lounge Restroom Faucet - South	20840300-002BF		ND			
3	Staff Lounge Restroom Faucet - North	20840300-003BF		ND			
4	Staff Lounge Kitchen Sink	20840300-0045F		ND			
5	Room 1 - Classroom Sink	20840300-005CF		2.8			
6	Room 1 - Classroom Drinking Fountain	20840300-006DW		4.56			
7	Room 2 - Classroom Sink	20840300-007CF		3.96			
8	Room 2 - Classroom Drinking Fountain	20840300-008DW		2.9			
9	Room 3 - Classroom Sink	20840300-009CF		ND			
10	Room 3 - Classroom Drinking Fountain	20840300-010DW		ND			
11	Restroom - Room 4 - Boys - North Sink	20840300-011BF		2.16			
12	Restroom - Room 4 - Boys - South Sink	20840300-012BF		3.91			
13	Restroom - Room 4 - Girls - North Sink	20840300-013BF		2.6			
14	Restroom - Room 4 - Girls - South Sink	20840300-014BF		6.1			
15	North Atrium Drinking Fountain	20840300-015DW		21.5	Removed from service 1/26/23	Water supply terminated	
16	New Wing Restroom Sink-Left to Right - 1	20840300-016BF		ND			
17	New Wing Restroom Sink-Left to Right - 2	20840300-017BF		ND			
18	New Wing Restroom Sink-Left to Right - 3	20840300-018BF		ND			
19	New Wing Restroom Sink-Left to Right - 4	20840300-019BF		ND			
20	Room 5 - Classroom Sink	20840300-020CF		ND			
21	Room 5 - Classroom Drinking Fountain	20840300-021DW		ND			
22	Room 6 - Classroom Sink	20840300-022CF		ND			
23	Room 6 - Classroom Drinking Fountain	20840300-023DW		ND			
24	Room 7 - Classroom Faucet	20840300-024CF		ND			
25	Room 7 - Classroom Drinking Fountain	20840300-025DW		ND			
26	Room 8 - Classroom Faucet	20840300-026CF		ND			
27	Room 8 - Classroom Drinking Fountain	20840300-027DW		ND			
28	Kallio Commons Sink	20840300-028CF		ND			
29	Kallio Commons Sink Sprayer	20840300-029CF		ND			
30	Room 9 - Classroom Sink	20840300-030CF		ND			
31	Room 9 - Classroom Drinking Fountain	20840300-031DW		ND			
32	Room 10 - Classroom Sink	20840300-032CF		ND			
33	Room 10 - Classroom Drinking Fountain	20840300-033DW		ND			
34	Room 11 - Classroom Sink	20840300-034CF		3.11			
35	Room 11 - Classroom Drinking Fountain	20840300-035DW		3.23			
36	Drinking Fountain Hallway North of Library Near Exit	20840300-036DW		2.86			
37	Room 12 - Classroom Sink	20840300-037CF		14.9			
38	Room 12 - Classroom Drinking Fountain	20840300-038DW		17	Removed from service 1/26/23	Water supply terminated	
39	Restroom - Boys - Near Room 13	20840300-039BF		ND			
40	Room 13 - Classroom Sink	20840300-040CF		19.3	Removed from service 1/26/23	Water supply terminated	
41	Room 13 - Classroom Drinking Fountain	20840300-041DW		32.1	Removed from service 1/26/23	Water supply terminated	
42	Room 14 - Classroom Sink	20840300-042CF		10.3			
43	Room 14 - Classroom Drinking Fountain	20840300-043DW		3.28			
44	Restroom - Girls - Near Room 14	20840300-044BF		ND			
45	Room 15 - Classroom Sink	20840300-045CF		18.1	Removed from service 1/26/23	Water supply terminated	
46	Room 15 - Classroom Drinking Fountain	20840300-046DW		12.3			
47	Room 17 - Classroom Sink	20840300-047CF		5.39			
48	Room 17 - Classroom Drinking Fountain	20840300-048DW		11.2			
49	Room 18 - Classroom Sink	20840300-049CF		10.5			
50	Room 18 - Classroom Drinking Fountain	20840300-050DW		7.39			
51	Room 19 - Classroom Sink	20840300-051CF		2.05			
52	Room 19 - Classroom Drinking Fountain	20840300-052DW		13.1			
53	Room 20 - Classroom Sink	20840300-053CF		6.23			
54	Room 20 - Classroom Drinking Fountain	20840300-054DW		18.5	Removed from service 1/26/23	Water supply terminated	
55	Room 21 - Classroom Sink	20840300-055CF		10.6			
56	Room 21 - Classroom Drinking Fountain	20840300-056DW		16.1	Removed from service 1/26/23	Water supply terminated	
57	Drinking Fountain Near Room 22	20840300-057DW		11.7			
58	Bottle Fill Fountain Near Room 22	20840300-058WB		4.7			
59	Gymnasium Restroom Sink - Left	20840300-059BF		ND			
60	Gymnasium Restroom Sink - Right	20840300-060BF		ND			
61	Gymnasium Drinking Fountain - Left	20840300-061DW		ND			
62	Gymnasium Drinking Fountain - Right	20840300-062DW		3.2			
63	Cafeteria Sink Faucet - Left	20840300-063CF		ND			
64	Cafeteria Sink Faucet - Middle	20840300-064CF		ND			
65	Cafeteria Sink Faucet - Right	20840300-065CF		2.77			
66	Cafeteria Sink Drinking Fountain	20840300-066DW		ND			
67	Cafeteria Restroom - Girls	20840300-067BF		ND			
68	Cafeteria Restroom - Boys	20840300-068BF		ND			
69	Kitchen - Hand Wash Sink - Left of Three (3) Well Sink	20840300-069KF		ND			
70	Kitchen - Three (3) Well Sink - Left	20840300-070KF		ND			
71	Kitchen - Three (3) Well Sink - Right	20840300-071KF		ND			
72	Kitchen - Dedicated Wall Sprayer Before Dishwasher	20840300-072KF		18.9	Removed from service 1/26/23	Water supply terminated	
73	Kitchen - Prep Sink - West Side of Room	20840300-073KF		ND			
74	Kitchen - Hand Wash Sink - West Side	20840300-074KF		ND			
75	Kitchen - Spray Wand on 3 well sink Faucet #71	20840300-075KF		ND			