

Fern Ridge Middle School (FRMS) - 208402			2022 Test				
Map Index #	Fixture Location/Description	Fixture ID #	Initial Collection Date	Result (ppb)	Action Taken	Comments	1st Retest Date
1	Front Office Health Room Restroom	20840200-001BF	2/1/2023	ND			
2	Left Drinking Fountain Outside Main Office	20840200-002DW	2/1/2023	ND			
3	Right Drinking Fountain Outside Main Office	20840200-003DW	2/1/2023	ND			
4	Bottle Fill Station Outside Main Office	20840200-004WB	2/1/2023	ND			
5	Drinking Fountain Between Rms. 14 and 15	20840200-005WC	2/1/2023	ND			
6	Staff Lounge Kitchen Sink	20840200-006SF	2/1/2023	ND			
7	Staff Lounge Instant How Water	20840200-007SF	2/1/2023	ND		Hot water	
8	Staff Lounge Sink Sprayer	20840200-008SF	2/1/2023	2.53		Taken with warm water	
9	Staff Lounge Restroom - Left	20840200-009BF	2/1/2023	ND			
10	Staff Lounge Restroom - Right	20840200-010BF	2/1/2023	ND			
11	Main Hallway Girls Bathroom - Left	20840200-011BF	2/1/2023	ND			
12	Main Hallway Girls Bathroom - Middle	20840200-012BF	2/1/2023	ND			
13	Main Hallway Girls Bathroom - Right	20840200-013BF	2/1/2023	ND			
14	Main Hallway Boys Restroom - Left	20840200-014BF	2/1/2023	ND			
15	Main Hallway Boys Restroom - Middle	20840200-015BF	--	--		No sample taken, faucet broken	
16	Main Hallway Boys Restroom - Right	20840200-016BF	2/1/2023	ND			
17	Drinking Fountain Between Rms. 16 and 17	20840200-017WC	2/1/2023	ND			
18	Bottle Fill Station Between Rms. 16 and 17	20840200-018WB	2/1/2023	2.21			
19	Room 20 - Classroom Sink	20840200-019CF	2/1/2023	3.19			
20	Room 20 - Classroom Drinking Fountain	20840200-020DW	2/1/2023	21.3			
21	Room 22 - West Wall Faucet - Left	20840200-021CF	2/1/2023	ND			
22	Room 22 - West Wall Faucet - Middle	20840200-022CF	2/1/2023	ND			
23	Room 22 - West Wall Faucet - Right	20840200-023CF	2/1/2023	ND			
24	Room 22 - East Wall Faucet - Left	20840200-024CF	2/1/2023	2.23			
25	Room 22 - East Wall Faucet - Middle	20840200-025CF	--	--		No sample taken, no water	
26	Room 22 - East Wall Faucet - Right	20840200-026CF	2/1/2023	ND			
27	Room 22 - South Wall Faucet	20840200-027CF	2/1/2023	ND			
28	Cafeteria Girls Restroom Faucet - Left	20840200-028BF	2/1/2023	ND			
29	Cafeteria Girls Restroom Faucet - Right	20840200-029BF	2/1/2023	ND			
30	Cafeteria Drinking Fountain	20840200-030WC	2/1/2023	ND			
31	Cafeteria Boys Restroom Faucet - Left	20840200-031BF	2/1/2023	ND			
32	Cafeteria Boys Restroom Faucet - Right	20840200-032BF	2/1/2023	ND			
33	Room 23 - Classroom Faucet - Left	20840200-033CF	2/1/2023	ND			
34	Room 23 - Classroom Faucet - Right	20840200-034CF	2/1/2023	ND			
35	Room 24 - East Wall Faucet	20840200-035CF	--	--		No sample taken. Removed from service	
36	Room 24 - West Wall Faucet	20840200-036CF	--	--		No sample taken. Removed from service	
37	Room 25 - Utility Sink	20840200-037CF	2/1/2023	7.36			
38	Room 27 - Classroom Sink	20840200-038CF	2/1/2023	2.4			
39	Room 27 - Classroom Drinking Fountain	20840200-039DW	2/1/2023	18.8			
40	Room 29 - Classroom Drinking Fountain	20840200-040DW	2/1/2023	ND			
41	Room 29 - Restroom Faucet - Left	20840200-041BF	2/1/2023	ND			
42	Room 29 - Restroom Faucet - Right	20840200-042BF	2/1/2023	ND			
43	Room 30 - Classroom Drinking Fountain	20840200-043DW	2/1/2023	ND			
44	Room 30 - Restroom Faucet - Left	20840200-044BF	2/1/2023	ND			
45	Room 30 - Restroom Faucet - Right	20840200-045BF	2/1/2023	ND			
46	Kitchen Small Handwash Sink	20840200-046KF	2/1/2023	ND			
47	Kitchen Three Well Sink	20840200-047KF	2/1/2023	ND			
48	Kitchen Sprayer Sink	20840200-048KF	2/1/2023	ND			